

Office of the Assistant Divisional Officer
Fire and Rescue Services, Kozhikode
PIN 673018
Phone: 0495 - 2321654
E mail: adokkd.frs@kerala.gov.in
Dated: 06.10.2017

No. D - 8537/17

INSPECTION CERTIFICATE

Ref : Request letter from the Manager, MES Fathima Rahim Central School,
Kaithapoyil, Kannothe P.O dated 14.09.2017.

.....

We have inspected MES Fathima Rahim Central School, Kaithapoyil, Kannothe P.O and the following Inspection report is issued:-

They have installed sufficient number of the Fire extinguishers which are in good working condition.

Fire exit and other staircases should always be properly kept so as to ensure the smooth and fast evacuation of students in emergency situations Exits should not be locked or blocked in any manner.

Sufficient Quantity of water / water sources have to be ensured always for fire fighting purpose.

Proper and frequent training should have to be given to the teachers, students and staff in building fire safety and also in operating fire fighting equipments and School Mock drills must be conducted once in 6 months.

Fire protection system as per National Building code Part IV should have to be installed for obtaining Fire NOC from this Department. But in this case, Fire NOC is not required as per Kerala Municipality / Panchayat Building Rules.

We have taken a training class to the Students, Teachers and Parents of the School on 27-10-2017.



Assistant Divisional Officer
Fire and Rescue Services,
Kozhikode.

To,

The Manager,
MES Fathima Rahim Central School,
Kaithapoyil, Kannothe P.O,
Kozhikode